

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. CR NO: 312/2025-26Date: 31/01/26

It is certified that an inspection team headed by concerned officials
of Town Municipal Council Kundapura (Name of Officers
with designation) from T.M.C Kundapura (Name of
Department/Office) inspected the Beary's Sea Side Public
School Kodi (Name & Address of
the School) on - and found that the Beary's Sea Side
Public School Kodi (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 2025-26.

Signature with Seal :

Anand J
Chief Officer
T.M.C., Kundapura

Name :

Anand J

Designation :

Chief officer

To

Principal
Beary's Sea Side
Public School Kodi

(Name & Address of the Institution)



Karnataka Gov.

RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

Udupi District Water Testing Laboratory, 1ST Floor, Old Zillapanchayath Building, Bannanje ,Udupi-576101

TEST REPORT

**Address : BEARYS SEASIDE PUBLIC SCHOOL ,
Bearys knowledge campus,
Beach road, Kodi,
Kundapur,-576217
Udupi district.**


Report date: 25.04.2025
Reference: Test Request form
Sample receipt date:23.04.2025
Sample code: NA
Date of Sample collection: 23.04.2025
Analysis start date: 24.04.2025
Analysis completion date: 24.04.2025
Sample collection protocol: APHA Method

Sample Particulars: Drinking Water

Sample quantity: 1 liter

Sl.No	Test	Results	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500 : 2012	Protocol
Description: Colourless liquid					
1.	pH Value @25°C	6.74	6.5 – 8.5	No relaxation	IS 3025 (Part-11) :2022
2.	Specific Conductance, µS/cm@25°C	231	NA	NA	IS 3025 (Part-14) :2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) :2021
5.	Turbidity, NTU	0.9	1	5	IS 3025 (Part-10) : 1984
6.	Total Dissolved Solids , mg/l	116	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO ₃ , mg/l	90.45	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO ₃ , mg/l	44.92	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	8.17	75	200	IS 3025 (Part-40) : 1991
10.	Magnesium as Mg, mg/l	5.95	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	24.82	250	1000	IS 3025 (Part-32) : 1988
12.	Sulphate as SO ₄ , mg/l	1.24	200	400	IS 3025 (Part-24) : 2022
13.	Fluoride as F, mg/l	0.57	1	1.5	APHA 24 th Edition
14.	Nitrate as NO ₃ , mg/l	0.058	45	No relaxation	APHA 24 th Edition
15.	Iron as Fe, mg/l	0.056	1	No relaxation	IS 3025 (Part-53) : 2003

Remarks: The above tested parameters are within the acceptable limit as per IS 10500:2012 drinking water specification.



(Signature)
(Nagaveni K.V , Technical Manager)
Authorized Signatory

RDWSD/WQMSP/TeR/01

- Note:**
- 1) The above results relate only to the sample tested.
 - 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
 - 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
 - 4) Samples will be discarded after 15 days from the date of report generation.
 - 5) Decision rules applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

-----END OF REPORT-----



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Divisional water quality testing laboratory, 1ST Floor, Old Zilla panchayath Building, Bannanje
Udupi-576101

TEST REPORT				
Location: Bearys Seaside Public School Bearys knowledge Campus, Beach road kodi, Kundapura- 576217 Udupi District.			Report date: 02.05.2025	
			Reference: Sample receipt form	
			Sample receipt date: 29.04.2025	
			Sample code: NA	
			Date of Sample collection: 29.04.2025	
			Analysis start date: 29.04.2025	
			Analysis completion date: 02.05.2025	
Sample collection protocol: NA				
Sample Particulars: Drinking water			Sample quantity:250 ML	
Sl. No.	Test	Results	Requirements	Protocol
1.	Total coliform /100ml	<1 MPN per 100 ml	Shall not be detectable in any 100 ml sample	IS 1622 :1981 RA 2018
2.	Faecal coliform /100ml	<1 MPN per 100 ml	Shall not be detectable in any 100 ml sample	IS 1622 :1981 RA 2018
3.	E. coli /100ml	<1 MPN per 100 ml	Shall not be detectable in any 100 ml sample	IS 1622 :1981 RA 2018
Remarks: The above given sample conform to limit as per IS 10500:2012 Drinking water specification for the above tested microbiological parameters only.				
<p style="text-align: center;"><i>W. Anela</i> 02.05.2025</p> Senior Microbiologist /Junior Microbiologist Analyzed by				

RDWSD/WQMSP/TeR/01

- Note:** 1) The above results relate only to the water sample tested.
2) Samples will be discarded after 7 days from the date of report generation for Microbiology parameters.

----- END OF THE REPORT-----

